



MIRA-BHAINDAR MUNICIPAL CORPORATION  
FIRE DEPARTMENT  
Tel. No. 2819 76 37 / 101



MBMC / FIRE / 19 / 2023-24

DATE: 04 / 04 / 2024

M/s. TAPOVAN VIDHYALAY DHAM,  
Indralok phase IV, opp. Sai Ram Tower,  
New Golden Nest Road, Bhayander (W)  
Dist Thane – 401 105



Sub.-Renewal No Objection Certificate for occupation of Proposed "Education Building" On plot Land bearing S.No./H.No. (Old) 228/9pt., 12pt, 13, 17, 235/2 (New) 27/9pt., 12pt, 13, 17, 31/2 at Village Uttan Bhayandar (W) Tal. & Dist. Thane.

**BUILDING RECOGNIZED AS "TAPOVAN VIDHYALAY DHAM"**

- Ref.:- 1) An Application received from M/s. TAPOVAN VIDHYALAY DHAM, DATE: 26/ 03/ 2024.  
2) Fire Fighting Maintenance Certificate of M/s. Vision Fire Safety Dated: 01/01/2024. (FORM B)  
3) Renewal N.O.C. MBMC/FIRE/ 132/ 2022-23 Dated. 27/ 04/ 2023.

With reference to above application dated on 26/ 03/ 2024 (Ref. No. 1) the party has submitted the Maintenance Report for the "Education Building Stilt G + 7 Floors" situated on the above mentioned address. From the point of view of fire prevention & protection provided by "M/s. ANISH & ASSOCIATES" Following Fire Fighting arrangements provided were found in satisfactory working condition as per the certificate issued by the Licensed Agency.

**A) Fire Hydrant System**

- 1) 1400 LPM, 56 Mtr Head Main pump – 01 No.
- 2) 180 LPM, 70 Mtr. Head Jockey pump – 01 No.
- 3) 450 LPM, 35 Mtr. Head 5 HP Booster pump – 01 No.
- 4) Control Panel for pump – 01 No.
- 5) S S Single Hydrant Valves – 16 Nos.
- 6) Hose Box – 02 Nos.
- 7) Canvas Pipe – 02 Nos.
- 8) Branch pipe – 02 Nos
- 9) 2 Way Breeching – 01 No.
- 10) Thermoplast hose reel pipe 20mtr long 20mm bore with hose drum and shut up nozzle – 14 Nos.
- 11) ABC type Fire Extinguisher 04 Kg Cap. – 09 Nos.

**B) Fire Alarm System**

- 1) 16 Zone Fire Alarm Control Panel – 02 Nos.
- 2) Manual Call Point – 14 Nos.
- 3) Electronic Hooter – 14 Nos.
- 4) Smoke Detector – 10 Nos.

Considering the same this Office is issuing **Renewal of final No Objection certificate** for the above mentioned building. This Certificate shall be treated valid up to **31/12/2024**. It is the responsibility of the owner / Architect / occupier to get the same renewed every year from the Fire Brigade Department after submitting inspection Report from Licensed Contractor twice in a year that is on 1<sup>st</sup> January and on 1<sup>st</sup> July. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The party has paid Inspection fees Rs. 50,223/- & Renewal fee of Rs. 1,100/- Vide Receipt No. 400798 Dated: 04/04/2024.

**A. CHIEF FIRE OFFICER**  
**FIRE & EMERGENCY SERVICES**  
**MIRA-BHAINDAR MUNICIPAL CORPORATION**

**Please Note:-** The Developer/Owner/Occupier have to Renew the N.O.C. on 1<sup>st</sup> Jan. of every year & submit the next Testing Certificate of firefighting system's from Licensed Agency appointed by Government of Maharashtra on 1<sup>st</sup> July of every year. The list of the License Agencies is available on [www.maharashtrafireservices.org](http://www.maharashtrafireservices.org) Or [www.mfsindia.org](http://www.mfsindia.org).